

Question 1.) Regarding the wall panel system our potential subcontractor recommends the cavity space between existing brick/CMU and the new panel system not be insulated. The panel system is designed to breath and insulation would hinder this. Mike Lundy also recommended the panel system should not be fastened directly to the existing brick/CMU because it could cause the panels to oxidize/corrode. Please advise on how to proceed.

Answer 1: Provide 2-1/4" X 1/4" masonry screws (tap con) X 2 (one each side (staggered 2")) of hat channel)) every 16 O.C and 3" from ends.
http://www.centria.com/ProductSpecifications_Anon/FWGS.pdf



2pnlOvrMasonry-Mo
del.pdf

Question 2: What is the amount required for the bid bond?

Answer 2: 20% of the bid price or \$3,000,000 whichever is less. (Will be included in amendment 0002)

Question 3: I have a question regarding the above referenced project. The liquidated damages clause is included in the solicitation documentation, but I did not see an amount. Can you please supply me with the liquidated damages amount?

Answer 3: \$191.20 for each of delay. (Will be included in amendment 0002)